




## Type Examination Certificate

**CML 18ATEX4072X Issue 1**

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **Lighting Fixtures EXENC-... Series**
- 3 Manufacturer **Cortem S.p.A.**
- 4 Address via Aquileia 10  
34070 Villesse  
Gorizia  
Italy
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 Certification Management Limited, Unit 1 Newport Business Park, New Port Road, Ellesmere Port CH65 4LZ, UK, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design of equipment intended for use in potentially explosive atmospheres given in Annex II of Directive 2014/34/EU.  
  
The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of certification (affecting correct installation or safe use). These are specified in Section 14.
- 8 This Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Annex VIII apply to the manufacture of the equipment or component.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:
 

EN 60079-0:2012+A11:2013	EN 60079-15:2010
EN 60079-28:2015	EN 60079-31:2014
- 10 The equipment shall be marked with the following:



II 3 G

Ex nA IIC T\*\* ... Gc

Ta = \*\*

\*\* See description



II 3 D

Ex tc IIIC T\* °C Dc

Ta = \*\*

\*\* See description



CML 18ATEX4072X  
Issue 1

## 11 Description

The Lighting Fixtures EXENC-... Series are luminaries suitable for use in Gas and Dust atmospheres.

They are constructed using a 2-part housing with lockable Polycarbonate transparent lid, hinged to a Polyester resin glass fibre reinforced base. The enclosure has an environmental rating of IP65, the manufacturer may claim a higher rating.

The enclosures contain electrical equipment for LED or Fluorescent Tube lighting sources mounted on internal frames. The Fluorescent Tube version is available with and without a rechargeable battery for either emergency and normal working.

The Lighting Fixtures EXENC-... Series consists of the following types:

EXENC-...	Fluorescent Tube lighting source for normal working only.
EXENC-...EE	Fluorescent Tube lighting source for emergency working only.
EXENC-...EF	Fluorescent Tube lighting source for normal working and emergency working.
EXENC-...L	LED lighting source for normal working only
EXENC-...LEE	LED lighting source for emergency working only
EXENC-...LEF	LED lighting source for normal working and emergency working

### Nomenclature:

**EXENC- a bb cc - dd e**

Where:

**EXENC-** Lighting Fixture Series

**a =** No. Fluorescent Tubes/ LED Strips

1 1 x Tube or 1 x LED Tube

2 2 x Tubes or 2 x LED Tube

**bb =** Power (W)

18 18 W Fluorescent Tube

36 36 W Fluorescent Tube

01 Short LED Tube LTT36700N

02 Medium LED Tube LTT72700N

**cc =** Model Type

None Fluorescent Tubes

L LED Strips

**dd =** Emergency Lighting Fixture

EF Normal + Emergency Working

EE Emergency Working Only

**e =** Emergency Unit Battery Rating

4 4 Ah

7 7 Ah



CML 18ATEX4072X  
Issue 1

The Lighting Fixtures EXENC-... Series are suitable for use in the following Maximum Surface Temperatures and ambient temperature ranges:

Fluorescent type EXENC-...

Type		Internal Battery Pack	Minimum Ambient Temperature	Temperature Class/ Maximum Surface Temperature		
				Tamb: +40°C	Tamb: +47°C	Tamb: +50°C
EXENC-1..	Normal Only	NO	-20°C	T4 / T55°C	T4 / T62°C	T3 / T65°C
EXENC-2..						
EXENC-1..EF	Normal + Emergency	YES	-20°C	T4 / T55 °C	T4 / T62°C	T3 / T65°C
EXENC-2..EF						
EXENC-1..EE	Emergency Only	YES	-20°C	T4 / T55 °C	T4 / T62°C	T3 / T65°C
EXENC-2..EE						

LED type EXENC-...L

Fixture Type		Internal Battery Pack	Minimum Ambient Temperature	Temperature Class/ Maximum Surface Temperature		
				Tamb: +40°C	Tamb: +47°C	Tamb: +50°C
EXENC-1..L	Normal only	NO	-40°C	T4 / T55°C	T4 / T62°C	N/A
EXENC-2..L						
EXENC-1..LEF	Normal + Emergency	YES	-20°C	T4 / T55°C	T4 / T62°C	N/A
EXENC-2..LEF						
EXENC-1..LEE	Emergency Only	YES	-20°C	T4 / T55°C	T4 / T62°C	N/A
EXENC-2..LEE						

The Lighting Fixtures EXENC-... Series has the following electrical ratings:

Rating - Fluorescent type EXENC-...

Type	Power Supply		Pilot Line		Battery pack	Power rating	
	INPUT VOLTAGE	INPUT FREQUENCY	INPUT VOLTAGE	INPUT FREQUENCY		bb=18	bb=36
EXENC-1..	220 – 240 Vac	50/60 Hz	100 – 240 Vac	50/60 Hz	4 Ah or 7 Ah 6 V	24W	41W
EXENC-2..						39W	68W
EXENC-1..EE	220 – 240 Vac	50/60 Hz	100 – 240 Vac	50/60 Hz	4 Ah or 7 Ah 6 V	24W	41W
EXENC-2..EE						39W	68W
EXENC-1..EF						24W	41W
EXENC-2..EF						39W	68W



CML 18ATEX4072X  
Issue 1

Rating - LED type EXENC-...L

Type	Power Supply		Pilot Line		Battery pack	Power rating	
	INPUT VOLTAGE	INPUT FREQUENCY	INPUT VOLTAGE	INPUT FREQUENCY		bb=01	bb=02
EXENC-1..L	220 – 240 Vac	50/60 Hz				13W	25W
EXENC-2..L						26W	52W
EXENC-1..LEE			100 – 240 Vac	50/60 Hz	4 Ah or 7 Ah 6 V	13W	25W
EXENC-2..LEE						26W	52W
EXENC-1..LEF	220 – 240 Vac	50/60 Hz				13W	25W
EXENC-2..LEF						26W	52W

**Variation 1**

This variation introduces the following changes:

- i. Changes to the model numbering system
- ii. The introduction of emergency working LED models
- iii. A change to the label marking which does not affect product certification

**12 Certificate history and evaluation Reports**

Issue	Date	Associated report	Notes
0	08-06-2018	R11426A-00	Initial Issue
1	29-10-2018	R11950A/00	The introduction of Variation 1

Note: Drawings that describe the equipment or component are listed in the Annex.

**13 Conditions of manufacture**

The following conditions are required of the manufacturing process for compliance with the certification.

- 13.1 All Ex Components fitted shall be installed in compliance with their schedule of limitations and manufacturer's instructions. All other equipment shall be installed in accordance with the requirements of the manufacturer's instructions. The manufacturer shall provide the installer/user copies of all Ex Equipment and Components certificates.
- 13.2 When marked 'nA' All creepage and clearance distances shall satisfy the requirements of IEC 60079-15 Table 2.
- 13.3 The manufacturer shall ensure that when Bi-pin non-sparking lampholders are installed, the contact pressures shall be adequate, and the pins of the lamp shall be supported to prevent distortion when they are subject to contact side pressure. The mechanical dimensions and the mounting conditions in the luminaire shall take into account the



CML 18ATEX4072X  
Issue 1

mechanical values and the tolerances specified for the type of lamp in IEC 60061-1, IEC 61195 and IEC 60400.

- 13.4 Each luminaire shall be subjected to a routine electric strength test at a test voltage of minimum 1,500 V r.m.s. for 60 s. There shall be no breakdown.

The use of a d.c. test voltage is allowed as an alternative to the specified a.c. test voltage and shall be minimum 2,100 V d.c.

**14 Specific Conditions of Use (Special Conditions)**

The following conditions relate to safe installation and/or use of the equipment.

- 14.1 Under certain extreme circumstances, exposed plastic and unearthed metal parts of the enclosure may store an ignition-capable level of electrostatic charge. Therefore, the user/installer shall implement precautions to prevent the build-up of electrostatic charge, e.g. locate the equipment where a charge-generating mechanism (such as wind-blown dust and steam generation) is unlikely to be present. Additionally, clean with a damp cloth or Antistatic Product.

- 14.2 All cable glands and plugs/stoppers for unused entries shall be suitable for use with the equipment and shall be:

- certified as Ex nA IIC Gc for EPL Gc, Ex tc IIIC Dc for EPL Dc
- Minimum IP54 for Gc and IP6X for Db and Dc. However, to maintain the maximum ingress protection level of the equipment, they shall be IP65 minimum. Additionally, they shall be suitable for the lower ambient temperature and an upper temperature of at least 15K above the upper ambient.

- 14.3 The battery pack used in the emergency lighting has a minimum service temperature of -20 °C only.

- 14.4 The Lighting Fixtures are manufactured from non-metallic materials that require installation in locations with respect to the risk of mechanical danger:

Types	Risk of Mechanical Danger
EXENC-136EF, EXENC-236EF; EXENC-136., EXENC-236.; EXENC-136EE, EXENC-236EE; EXENC-102L, EXENC-202L; EXENC-102LEE, EXENC-202LEE; EXENC-102LEF, EXENC-202LEF;	Low
EXENC-118EF, EXENC-218EF; EXENC-118., EXENC-218.; EXENC-118EE, EXENC-218EE; EXENC-101L EXENC-201L; EXENC-101LEE EXENC-201LEE; EXENC-101LEF EXENC-201LEF;	High

## Certificate Annex

**Certificate Number** CML 18ATEX4072X  
**Equipment** Lighting Fixtures EXENC -... Series  
**Manufacturer** Cortem S.p.A.



The following documents describe the equipment or component defined in this certificate:

### Issue 0

Drawing No	Sheets	Rev	Approved date	Title
A3-6707	1 of 6	0	08-06-2018	Lighting Fixture Series EXEN-..C.. Assembly and External Dimensions
A3-6707	2 of 6	0	08-06-2018	Lighting Fixture Series EXEN-..C.. Assembly and External Dimensions
A3-6707	3 of 6	0	08-06-2018	Lighting Fixture Series EXEN-..C.. Assembly and External Dimensions
A3-6707	4 of 6	0	08-06-2018	Lighting Fixture Series EXEN-..C.. Labelling and Gaskets
A3-6707	5 of 6	0	08-06-2018	Lighting Fixture Series EXEN-..C.. Assembly and External Dimensions
A3-6707	6 of 6	0	08-06-2018	Lighting Fixture Series EXEN-..C.. Assembly and External Dimensions
A3-7132	1 of 2	0	08-06-2018	LED Tube LTT..N Creepage distances/ Creepage Distances / Clearances
A3-7132	2 of 2	0	08-06-2018	LED Tube LTT..N Creepage distances/ Clearances
A4-6708	1 to 7	0	08-06-2018	Technical Note Explosion Proof Luminaries Series EXEN-..C..
A2-7177	1 of 1	-	08-06-2018	EXEN-218C Enclosure Thicknesses and Hinges
A3-7177	1 of 1	-	08-06-2018	EXEN-236C Enclosure Thicknesses and Hinges

### Issue 1

Drawing No	Sheets	Rev	Approved date	Title
A3-7245	1 to 2	0	29-10-2018	Lighting fixture series EXENC-..L electrical circuit
A4-7246	1 to 4	0	29-10-2018	Luminaire series EXENC... Technical note