



CESI S.p.A.
 Via Rubattino 54
 I-20134 Milano - Italy
 Tel: +39 02 21251
 Fax: +39 02 2125440
 e-mail: info@cesi.it
 www.cesi.it

Schema di certificazione

CESI-ATEX

[1] **SUPPLEMENTARY EU-TYPE EXAMINATION CERTIFICATE**

[2] **Component intended for use on/in equipment or protective system intended for use in potentially explosive atmospheres Directive 2014/34/EU**

[3] Supplementary EU-Type Examination Certificate number:
CESI 00 ATEX 036 U /07

[4] Component: **Empty enclosures series CCF and EJB for control and signalling equipment**

[5] Manufacturer: **COR.TEM S.p.A.**

[6] Address: **Via Aquileia, 12 – 34070 Villesse (GO) – Italy**

[7] This supplementary certificate extends EC-Type Examination Certificate CESI 00 ATEX 036U, to apply to products designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

[8] CESI, notified body n. 0722 in accordance with Article 17 of the Directive 2014/34/EU of the Parliament and Council of 26 February 2014, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report n. EX-B6023467.

[9] In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016

[10] The sign "U" placed after the certificate number indicates that this certificate must not be mistaken for a certificate intended for an equipment or protective system. This partial certification may be used as a basis for certification of an equipment or protective system.

[11] This EU-TYPE EXAMINATION CERTIFICATE relates only to the design, examination and tests of the specified component in accordance to the Directive 2014/34/EU. Further requirements of the Directive apply to the manufacturing process and supply of this component. These are not covered by this certificate.

[12] The marking of the component shall include the following:

	II 2 G	Ex db IIB Gb	<i>or</i>	Ex db IIB+H2 Gb
	I M2	Ex db IMb		<i>(Stainless Steel enclosures only)</i>
	II 2 G D	Ex db IIB Gb	<i>or</i>	Ex db IIB+H2 Gb
		Ex tb IIIC Db		Ex tb IIIC Db
		IP66/67		IP66/67

This certificate may only be reproduced in its entirety and without any change, schedule included.

Date 2016.09.26 - Translation issued the 2016.09.26

Prepared
 Alessandro Fedato

Verified
 Mirko Balaz

Approved
 Roberto Piccin

CESI S.p.A.
 Testing & Certification Division
 Business Area Certification
 Il Responsabile
 (Roberto Piccin)



[13]

Schedule

[14] SUPPLEMENTARY EU-TYPE EXAMINATION CERTIFICATE n. CESI 00 ATEX 036 U /07

[15] **Description of the variation to the component**

- Updating to standards EN 60079-0: 2012 + A11:2013, EN60079-1:2014 and EN60079-31:2014.
- New minimum ambient temperature -60°C.
- Upgrade to EJB design (new 2015 series) and EJBX series.
- New enclosures type EJBX-01 was added.
- New enclosures EJBT... series was added.

Description of component

The **EJB-..** empty enclosures series have the body and the cover made in aluminium alloy or stainless steel and are in Ex d I (stainless steel only), Ex d IIB, Ex d IIB+H₂ and Ex tb IIIC execution.

The **EJB-..** series is available in two particular execution:

- with external flange for type **EJB-..**;
- with internal flange for type **AQS-1**.

They can be equipped with command and signalling operators series M-0.. certified as components with separate certificate, mounted on the cover or on the enclosure wall and with circular or rectangular transparent tempered glass windows sealed on the cover. Gaskets between cover and body flanged joint and for all other accessories are made in silicon and they guarantee the protection degree IP66 while IP67 for enclosures without operators only. The flanged joint between the body of **EJB-..** empty enclosures series and the cover is fixed with quality A2-70 stainless steel screws.

The walls of the enclosures can be drilled and threaded with maximum size and maximum number of hubs as specified in the manufacturer documents annexed. Each enclosure is provided with internal and external earthing screw or bolt and an internal bottom plate for equipment mounting.

Model identification:

Aluminium alloy enclosures		Stainless steel enclosures
EJB series	EJBT series	EJBX series
AQS-1	-	-
EJB-01	EJBT0	EJBX-01
-	-	EJBX-01B
EJB-1	EJBT1	EJBX-1
EJB-2	EJBT2	EJBX-2
-	EJBT2CB	-
-	EJBT2C	-
EJB-3	EJBT3	EJBX-3
EJB-3B	EJBT3B	EJBX-3B
EJB-4	EJBT4	EJBX-4
EJB-4B	EJBT4B	EJBX-4B
EJB-45	EJBT45	EJBX-45
EJB-45B	EJBT45B	EJBX-45B
EJB-48BA	-	-
EJB-5	EJBT5	EJBX-5
EJB-5B	EJBT5B	EJBX-5B
EJB-55	EJBT55	EJBX-55
EJB-55B	EJBT55B	EJBX-55B
EJB-503	-	-
EJB-55C	-	-
EJB-6	EJBT6	EJBX-6
EJB-6B	EJBT6B	EJBX-6B
EJB-7	EJBT7	EJBX-7
EJB-7B	-	-

This certificate may only be reproduced in its entirety and without any change, schedule included.

[13]

Schedule

[14] SUPPLEMENTARY EU-TYPE EXAMINATION CERTIFICATE n. CESI 00 ATEX 036 U /07

Ambient temperature ranges

- from -20°C up to +60°C: all versions of empty enclosures for group I (made in stainless steel only), group IIB, IIB+H₂ and group IIIC;
- from -40°C up to +60°C: all versions of empty enclosures for group IIB, IIB+H₂ and group IIIC with polycarbonate pilot lights;
- from -60°C up to +60°C: all versions of empty enclosures for group IIB, IIB+H₂ and group IIIC without polycarbonate pilot lights;
- from -60°C up to +100°C: all versions of empty enclosures (types EJB-01 and AQS-1 excluded) for group IIB and group IIIC with or without glass windows sealed on the cover and without control-signal operators.

Cable entries

The accessories used for cable entries and plugs for not used holes shall be subject of separate certification, suitable for type of enclosure execution, according to the applicable standards.

[16] Report n. EX- B6023467.

Routine tests

The routine overpressure test shall be carried out on empty enclosure with the static method (paragraph 15.2.3.2 of EN 60079-1 Standard), at:

- 14.0 bar on all EJB enclosures for minimum ambient temperature until -20 °C;
- 16.0 bar on all EJB enclosures for minimum ambient temperature until -60 °C.

[17] Schedule of limitations

- The accessories used for cable entries and for closing unused openings shall be certified according to EN 60079-0, EN 60079-1 and EN 60079-31. A minimum degree of protection IP66/67 shall be guaranteed according to EN 60529 standard.
- The empty enclosures shall be used in the following ambient temperature range:
 - from -20°C up to +60°C: all versions of empty enclosures for group I (made in stainless steel only), group IIB, IIB+H₂ and group IIIC;
 - from -40°C up to +60°C: all versions of empty enclosures for group IIB, IIB+H₂ and group IIIC with polycarbonate pilot lights;
 - from -60°C up to +60°C all versions of empty enclosures for group IIB, IIB+H₂ and group IIIC without polycarbonate pilot lights.
 - from -60°C up to +100°C: all versions of empty enclosures (types EJB-01 and AQS-1 excluded) for group IIB and group IIIC with or without glass windows sealed on the cover and without control-signal operators.
- Maximum service temperature of the empty enclosures:
 - +100 °C for all versions of empty enclosures.
 - +150 °C for empty enclosures of group II and III, without control-signal operators and windows.
- The service temperature range of the components installed into the enclosures shall be taking into account.
- The minimum distance between flameproof flanged joint of the enclosure and external obstacle should be:
 - 20 mm for IIB execution.
 - 30 mm for IIB+H₂ execution.
- According to EN 60079-1 annex D, the content of the Ex component enclosure equipment may be placed in any arrangement, provided that:
 - for group I an area of at least 20% of each cross-sectional area remains free;
 - for groups IIB and IIB+H₂ an area of at least 40% of each cross-sectional area remains free.

[13]

Schedule

[14] **SUPPLEMENTARY EU-TYPE EXAMINATION CERTIFICATE n. CESI 00 ATEX 036 U /07**

[18] **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements has been assured by compliance to the following standards:

EN 60079-0: 2012 + A11:2013 – Explosive atmospheres – Part 0: Equipment - General requirements;

EN 60079-1: 2014 Explosive atmospheres – Part 1: Equipment protection by flameproof enclosure “d”;

EN 60079-31: 2014 Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure “t”.

[19] **Descriptive documents** (prot. EX- B6023470).

- Technical note A4-6356 (pg. 8)	rev.0	dated	2016.06.16
- Safety, maintenance and mounting instructions F-276A (pg. 9)	rev.4	dated	2016.06.16
- Attestation of Conformity Facsimile no. 0018 (pg. 1)		dated	2016.06.16
- Drawing no. A3-6355 (3 sheets)	rev.0	dated	2015.04.16
- Drawing no. A3-5604 (2 sheets)	rev.1	dated	2015.04.16
- Drawing no. A3-5025 (4 sheets)	rev.2	dated	2015.04.16
- Drawing no. A1-4232 (1 sheet)	rev.6	dated	2015.04.16
- Drawing no. A1-4097 (1 sheet)	rev.4	dated	2015.04.16
- Drawing no. A3-5044 (3 sheets)	rev.1	dated	2015.04.16
- Drawing no. A2-4137 (2 sheets)	rev.4	dated	2015.06.01
- Drawing no. A3-5028 (2 sheets)	rev.1	dated	2015.04.16
- Drawing no. A1-4098 (1 sheet)	rev.4	dated	2015.04.16
- Drawing no. A1-4094 (1 sheet)	rev.4	dated	2015.04.16
- Drawing no. A4-4129 (2 sheets)	rev.2	dated	2013.01.25
- Drawing no. A1-4096 (1 sheet)	rev.3	dated	2015.04.16
- Drawing no. A1-4095 (1 sheet)	rev.3	dated	2015.04.16
- Drawing no. A3-5916 (3 sheets)	rev.1	dated	2015.04.16
- Drawing no. A3-5422 (1 sheet)	rev.2	dated	2015.04.16
- Datasheet of materials (21 sheets)	rev.0	dated	2015.04.16

One copy of all documents is kept in CESI files.

Certificate history

Issue nr	Issue Date	Summary description of variation
07	2016.09.26	Updating to standards EN 60079-0: 2012 + A11:2013, EN60079-1:2014 and EN60079-31:2014. New minimum ambient temperature -60°C. Upgrade to EJB design (new 2015 series) and EJBX series. New enclosures type EJBX-01 and EJBT... series were added.
06	2012.03.16	Updating to standards EN60079-0:2009, EN60079-1:2007 and EN60079-31:2009. New size EJB-55B was added, updating to EJB-55 and EJB-55C codes.
05	2009.07.23	Updating to standard EN 60079-1: 2007, positioning of O-ring on the cover, new sizes type EJB-7 and EJB-7B were added, new min. ambient temperature ranges for group II.
04	2007.11.19	Updating to standards EN60079-0:2006, EN60079-1:2004, EN61241-0:2006 and EN61241-1:2004. New models of box type EJB., and EJBX., new exec. IIB+H ₂ and I M2. New service and ambient temperature ranges.
03	2003.10.08	Use of rectangular glass windows with major dimensions.
02	2003.02.26	New degree of protection IP65 or IP66/67. New category II2GD for gases and dusts and use of rectangular glass windows.
01	2002.06.26	New CCFE-01 and AQS.-1 type were added.
00	2000.07.24	First Issue of the Certificate.